

Water Age Computation for Distribution Networks

Auteur : Stoquart, Colin

Promoteur(s) : Dewals, Benjamin; Archambeau, Pierre

Faculté : Faculté des Sciences appliquées

Diplôme : Master en ingénieur civil physicien, à finalité approfondie

Année académique : 2020-2021

URI/URL : <http://hdl.handle.net/2268.2/11447>

Avertissement à l'attention des usagers :

Tous les documents placés en accès ouvert sur le site le site MatheO sont protégés par le droit d'auteur. Conformément aux principes énoncés par la "Budapest Open Access Initiative"(BOAI, 2002), l'utilisateur du site peut lire, télécharger, copier, transmettre, imprimer, chercher ou faire un lien vers le texte intégral de ces documents, les disséquer pour les indexer, s'en servir de données pour un logiciel, ou s'en servir à toute autre fin légale (ou prévue par la réglementation relative au droit d'auteur). Toute utilisation du document à des fins commerciales est strictement interdite.

Par ailleurs, l'utilisateur s'engage à respecter les droits moraux de l'auteur, principalement le droit à l'intégrité de l'oeuvre et le droit de paternité et ce dans toute utilisation que l'utilisateur entreprend. Ainsi, à titre d'exemple, lorsqu'il reproduira un document par extrait ou dans son intégralité, l'utilisateur citera de manière complète les sources telles que mentionnées ci-dessus. Toute utilisation non explicitement autorisée ci-avant (telle que par exemple, la modification du document ou son résumé) nécessite l'autorisation préalable et expresse des auteurs ou de leurs ayants droit.

ACADEMIC YEAR 2020-2021
FACULTY OF APPLIED SCIENCES
ENGINEERING PHYSICS
AUTHOR: COLIN STOQUART
ADVISOR: PROF. B. DEWALS
ADVISOR: PROF. P. ARCHAMBEAU



Water Age Computation for Distribution Networks

ABSTRACT

As you start reading these lines, you may have already taken a shower, drank tap water, started a washing machine, or any of these small daily miracles that a water distribution system offers us. The omnipresence of water distribution networks (WDNs) in our daily life may lead us to reduce WDNs to simple and well-understood systems, which they are not. Among many concerns for WDNs, a major and essential one is to ensure to every customer good water quality. A well-known technique to easily assess water quality is to evaluate the water age ([1], [3], [5]).

In this work, two existing methods to evaluate the water age in WDNs have been reviewed and implemented: the flow weighted method from the software EPANET [7], and the bins method introduced by Machel et al. [4]. First, assuming steady-state, a method with a new representation of the age distribution has been implemented. This last method is shown to be more accurate and more computationally efficient. It has been successfully applied on a full-scale network. Some models to extend this new method to unsteady-state have been reviewed and implemented. The new method is shown to not include any further complication compared to the already existing methods.

All the previously cited methods make two common assumptions: the complete mixing at the junctions and the plug flow assumption. These two hypotheses have been shown to be inaccurate by several authors ([6], [8], [2]). In the second part of this work, numerical techniques are developed to model more complex phenomena on academic networks. Some non-homogeneous mixing models are reviewed and implemented with the newly developed method. Dispersion effects are modelled thanks to an approximate analytical solution and a finite volume scheme to go beyond the plug flow assumption. The optimal model to consider the dispersion effects is shown to depend on the Peclet number in each pipe of the network.

References

- [1] Walter M. Grayman, Regan Murray, and Dragan A. Savic. *Effects of Redesign of Water Systems for Security and Water Quality Factors*, pages 1–11.
- [2] Clifford K Ho. Solute mixing models for water-distribution pipe networks. *Journal of Hydraulic Engineering*, 134(9):1236–1244, 2008.
- [3] Nikolaos Kourbasis, Menelaos Patelis, Stavroula Tsitsifli, and Vasilis Kanakoudis. Optimizing water age and pressure in drinking water distribution networks. In *Environmental Sciences Proceedings*, volume 2, page 51. Multidisciplinary Digital Publishing Institute, 2020.
- [4] John Machell, Joby Boxall, Adrian Saul, and Dylan Bramley. Improved representation of water age in distribution networks to inform water quality. *Journal of Water Resources Planning and Management*, 135(5):382–391, 2009.
- [5] William J Rhoads, Amy Pruden, and Marc A Edwards. Survey of green building water systems reveals elevated water age and water quality concerns. *Environmental Science: Water Research & Technology*, 2(1):164–173, 2016.
- [6] P Romero-Gomez, Z Li, CY Choi, SG Buchberger, Kevin E Lansey, and VT Tzatchkov. Axial dispersion in a pressurized pipe under various flow conditions. In *Water Distribution Systems Analysis 2008*, pages 1–10. 2008.
- [7] Lewis A. Rossman, Hyounghmin Woo, Michael Tryby, Feng Shang, Robert Janke, and Terranna Haxton. *EPANET 2.2 User Manual*. U.S. Environmental Protection Agency, https://epanet22.readthedocs.io/_/downloads/en/latest/pdf/, epa/600/r-20/133 edition.
- [8] Yu Shao, Y Jeffrey Yang, Lijie Jiang, Tingchao Yu, and Cheng Shen. Experimental testing and modeling analysis of solute mixing at water distribution pipe junctions. *Water research*, 56:133–147, 2014.